

Location: Pohorje, Slovenia

Id: 352656101010101

Voltage: 110 kV

No	Date of report	Time	Surge arrester condition	Temperature of device	Surge counter	Device deviation
1	24.11.2020	23:29"	0.44 mA	-3.0 °C	0	●
2	23.11.2020	23:29"	0.41 mA	0.0 °C	0	●
3	22.11.2020	23:29"	0.39 mA	-2.0 °C	0	●
4	21.11.2020	01:29"	0.39 mA	4.0 °C	0	●
5	20.11.2020	23:29"	0.40 mA	4.0 °C	0	●
6	19.11.2020	23:29"	0.44 mA	1.0 °C	0	●
7	17.11.2020	23:29"	0.33 mA	4.0 °C	0	●
8	16.11.2020	23:29"	0.27 mA	6.0 °C	0	●
9	15.11.2020	23:29"	0.39 mA	7.0 °C	0	●
10	14.11.2020	01:29"	0.32 mA	°C	0	●
11	13.11.2020	23:29"	0.30 mA	1.0 °C	0	●
12	12.11.2020	23:29"	0.28 mA	1.0 °C	0	●
13	11.11.2020	23:29"	0.29 mA	3.0 °C	0	●
14	10.11.2020	23:29"	0.29 mA	3.0 °C	0	●
15	09.11.2020	23:29"	0.28 mA	3.0 °C	0	●
16	08.11.2020	23:29"	0.35 mA	3.0 °C	0	●
17	07.11.2020	00:30"	0.30 mA	3.0 °C	0	●
18	06.11.2020	23:29"	0.27 mA	3.0 °C	0	●
19	05.11.2020	23:29"	0.28 mA	9.0 °C	0	●
20	04.11.2020	23:29"	0.27 mA	11.0 °C	0	●
21	03.11.2020	23:29"	0.27 mA	9.0 °C	0	●
22	31.10.2020	00:30"	0.37 mA	8.0 °C	0	●
23	28.10.2020	23:30"	0.38 mA	4.0 °C	0	●
24	27.10.2020	23:30"	0.39 mA	8.0 °C	0	●
25	26.10.2020	23:30"	0.35 mA	16.0 °C	0	●
26	25.10.2020	00:30"	0.34 mA	12.0 °C	0	●
27	24.10.2020	02:30"	0.37 mA	13.5 °C	0	●
28	22.10.2020	00:30"	0.36 mA	10.0 °C	0	●
29	21.10.2020	00:30"	0.40 mA	5.0 °C	0	●
30	20.10.2020	00:30"	0.38 mA	3.0 °C	0	●