

Location: Pohorje, Slovenia

Id: 352656101010100

Voltage: 20 kV

No	Date of report	Time	Surge arrester condition	Temperature of device	Surge counter	Device deviation
1	25.11.2020	01:28"	< 0.03 mA	-3.0 °C	0	●
2	24.11.2020	01:28"	< 0.03 mA	-1.0 °C	0	●
3	23.11.2020	01:28"	< 0.03 mA	2.0 °C	0	●
4	22.11.2020	01:28"	< 0.03 mA	-6.0 °C	0	●
5	21.11.2020	03:28"	< 0.03 mA	-3.0 °C	0	●
6	20.11.2020	01:28"	< 0.03 mA	2.0 °C	0	●
7	18.11.2020	01:28"	< 0.03 mA	2.0 °C	0	●
8	17.11.2020	01:28"	< 0.03 mA	3.0 °C	0	●
9	16.11.2020	01:28"	< 0.03 mA	6.0 °C	0	●
10	15.11.2020	01:28"	< 0.03 mA	4.0 °C	0	●
11	14.11.2020	03:28"	< 0.03 mA	1.0 °C	0	●
12	12.11.2020	00:28"	< 0.03 mA	-1.0 °C	0	●
13	11.11.2020	00:28"	< 0.03 mA	-3.0 °C	0	●
14	10.11.2020	00:28"	< 0.03 mA	4.0 °C	0	●
15	09.11.2020	00:28"	< 0.03 mA	5.0 °C	0	●
16	08.11.2020	00:28"	< 0.03 mA	5.0 °C	0	●
17	07.11.2020	02:28"	< 0.03 mA	3.0 °C	0	●
18	06.11.2020	00:28"	< 0.03 mA	4.0 °C	0	●
19	05.11.2020	00:28"	< 0.03 mA	7.0 °C	0	●
20	04.11.2020	00:28"	< 0.03 mA	10.0 °C	0	●
21	03.11.2020	00:28"	< 0.03 mA	10.0 °C	0	●
22	01.11.2020	00:28"	< 0.03 mA	7.0 °C	0	●
23	31.10.2020	00:28"	< 0.03 mA	9.0 °C	0	●
24	29.10.2020	00:28"	< 0.03 mA	4.0 °C	0	●
25	28.10.2020	00:28"	< 0.03 mA	4.0 °C	0	●
26	27.10.2020	00:28"	< 0.03 mA	9.0 °C	0	●
27	25.10.2020	01:28"	< 0.03 mA	8.0 °C	0	●
28	24.10.2020	03:28"	< 0.03 mA	9.5 °C	0	●
29	22.10.2020	01:28"	< 0.03 mA	6.0 °C	0	●
30	21.10.2020	01:28"	< 0.03 mA	5.0 °C	0	●